

CERTIFICATE OF ADMITTANCE

No. 4764/2022

Based on art. 7 paragraph 2 of the Act of 24 August 1991 on fire protection
Centrum Naukowo-Badawcze Ochrony Przeciwpózarowej im. Józefa Tuliszowskiego
Państwowy Instytut Badawczy at the request of:

Intelight Sp. z o. o.
ul. Gwiazdzista 19
01-651 Warszawa

states that product:

Luminaire for emergency lighting type AURA

Varieties of luminaire are given on page 2 of the certificate of admittance.

manufactured by:

Intelight Sp. z o. o.
ul. Gwiazdzista 19
01-651 Warszawa

in the manufacturing plant:

Intelight Sp. z o. o.
Poczernin 46
09-142 Żałuski

meets the requirements of:

pt. 13.2 of annex to the Regulation of the Minister of the Interior
and Administration of 20 June 2007 on the list of products used for ensuring
public safety or protecting health, life and property, and the principles
of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143
poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z 2022 r. poz.
2282)

Documentation:

1. Application for the process of product admittance No. 6581/2022 of 08.06.2022 and application for changing the admittance No. 6770/2023 of 03.01.2023.
2. Test report No. 393/BA/22 of 30.09.2022 and No. 866/BA/23 of 03.03.2023 issued by Zespół Laboratoriów Sygnalizacji Alarmu Pożaru i Automatyki Pożarniczej (BA) CNBOP-PIB.

The certificate of admittance is valid under the condition that the applicant fulfils the requirements defined in the agreement No. 4764/DC/CNBOP-PIB/2022.

Validity period of the admittance:

from 14.06.2024

until 17.10.2027

DIRECTOR OF CNBOP-PIB



st. bryg. Paweł Janik, PhD Eng.



Józefów: 14 June 2024

Page 1/3

*This document was originally translated from Polish to English on 03 July 2024.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*

Replaces certificate of admittance No. 4764/2022 of 18.10.2022.

CERTIFICATE OF ADMITTANCE

No. 4764/2022


TECHNICAL DATA IDENTIFYING THE PRODUCT

Luminaire for emergency lighting type AURA in varieties:

Name	Measurement	Operation mode	Autonomy	Performance	Colour temperature
AURA	60x60 120x30	M	1H 2H 3H	MT AT	3000K 4000K 5000K 6500K
AURA	60x60 120x30	---	---	CB	3000K 4000K 5000K 6500K

CNBOP-PIB

DIRECTOR OF CNBOP-PIB



st. bryg. Paweł Janik, PhD Eng.



Józefów: 14 June 2024

Page 2/3

*This document was originally translated from Polish to English on 03 July 2024.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*

Replaces certificate of admittance No. 4764/2022 of 18.10.2022.

CERTIFICATE OF ADMITTANCE
No. 4764/2022

TECHNICAL DATA IDENTIFYING THE PRODUCT

Luminaire for emergency lighting type AURA

Varieties of luminaire are given on page 2 of the certificate of admittance.

Type	AURA	
	Z - central supply (varieties: CB);	X - self-contained (varieties: MT, AT);
Operation mode	1 - maintained;	1 - maintained;
Accessories	not applicable	A - including test device; F - automatic test gear complying with IEC 61347-2-7, marked as EL-T (varieties: AT, CT);
Rated emergency operating time	not applicable (parameter of supply systems)	60 - 1 hour of emergency operating time; 120 - 2 hours of emergency operating time; 180 - 3 hours of emergency operating time;
Rated supply voltage	230 V AC 50 Hz, 220 V DC	230 V AC 50 Hz
Protection class against electric shock	I	
Ingress protection rating to dust, solids and water	IP20	
Light source	LED module	
Battery charging time	not applicable (parameter of supply systems)	not exceeding 24 h
Battery charging indication	not applicable (function of supply systems)	yes – LED diode
Adapted to pictograms	no	
Mounting method	surface, recessed, suspended	
Mounting surface (in accordance with PN-EN 60598-1)	normally flammable surfaces	
Conditions of use (in accordance with PN-EN 60598-1)	for normal use	
Material of housing	metal (<i>housing</i>), plastic (<i>diffuser</i>)	
<i>Self-contained luminaires in AT and CT varieties are intended for automatic test systems in accordance with the standard PN-EN 62034:2012.</i>		

ADDITIONAL CONDITIONS AND COMMENTS:

According to § 17 of the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z-2022 r. poz. 2282) a product should be marked with the marking of the admittance body and also the number of the certificate of admittance.

The following editions of the standards were used in the admittance process:

- PN-EN IEC 60598-1:2021-07+A1+A11:2022-12
- PN-EN IEC 60598-2-22:2022-11

DIRECTOR OF CNBOP-PIB



st. bryg. Paweł Janik, PhD Eng.



Józefów: 14 June 2024

Page 3/3

*This document was originally translated from Polish to English on 03 July 2024.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*

Replaces certificate of admittance No. 4764/2022 of 18.10.2022.